

福島県原子力発電所周辺環境放射能測定結果（速報）

平成30年度（平成30年9月） 測定分

1 測定項目

（１）空間放射線

項 目	計画地点数	調査地点数 (9月)	測 定 頻 度	実 施 機 関
空 間 線 量 率	39	39	連 続	環境創造センター
空 間 積 算 線 量	64	64	3 カ 月 積 算	

（２）環境試料

区 分	試 料 名	計画地点数	調査地点数 (9月)	採取回数 (9月)	採取頻度	測 定 試 料 数 (9月)							実施機関
						全β	γ	¹³¹ I	³ H	Sr	Pu	Am,Cm	
大 気	大気浮遊じん	17	17	1	毎月	連続 全α全β	17						環境創造 センター
		25	25	1			25						
	大気中水分	5	5	1	毎月				5				
降 下 物	降 下 物	10	10	1	毎月		10						
土 壌	土 壌	15	0	0	年2回		0						
					年1回					0	0	0	
陸 上	水 上 水	13	0	0	年4回		0		0				
					年1回					0	0		
海 水	海 水	6(*1)	6(*1)	1	毎月	6	6		6	6	6		
		2(*2)	2(*2)	1	年4回	2	2		2				
			0	0	年1回					0	0		
海 底 土	海 底 土	6(*1)	0	0	年4回		0			0	0		
		2(*2)	2(*2)	1	年4回		2						
			0	0	年1回					0	0		
指 標 植 物	松 葉	15	0	0	年4回		0	0					

*1 東京電力ホールディングス（株）福島第一原子力発電所周辺海域

*2 東京電力ホールディングス（株）福島第二原子力発電所周辺海域

2 測定項目（比較対照地点調査）

（１）空間放射線

項 目	計画地点数	調査地点数 (9月)	測 定 頻 度	実 施 機 関
空 間 線 量 率	3	3	連 続	環境創造センター

（２）環境試料

区 分	試 料 名	計画地点数	調査地点数 (9月)	採取回数 (9月)	採取頻度	測 定 試 料 数 (9月)							実施機関
						全β	γ	¹³¹ I	³ H	Sr	Pu	Am,Cm	
大 気	大気浮遊じん	7	7	1	毎月		7						環境創造 センター
	大気中水分	1	1	1					1				
降 下 物	降 下 物	2	2	1	毎月		2						
土 壌	土 壌	7	0	0	年1回		0			0	0		
		1										0	
陸 上	水 上 水	2	0	0	年1回		0		0				
		1								0	0		
海 水	海 水	1	1	1	年1回	1	1		1	1	1		
海 底 土	海 底 土	1	1	1	年1回		1			1	1		
指 標 植 物	松 葉	5	0	0	年4回		0	0					

（注）次ページ以降の黄色網掛け部分が、今回の公表分です。

[illegible]

No.	測定年月 測定項目 測定地点名	H30.4		5		6		7		8		9		10		11		12		H31.1		2		3	
		線量 率	測定 時間	線量 率	測定 時間	線量 率	測定 時間	線量 率	測定 時間	線量 率	測定 時間	線量 率	測定 時間	線量 率	測定 時間	線量 率	測定 時間	線量 率	測定 時間	線量 率	測定 時間	線量 率	測定 時間	線量 率	測定 時間
28	浪江町 請 戸 *1	115 (132)	720	114 (133)	744	114 (128)	720	119 (127)	744	120 (133)	744	115 (132)	720												
29	浪江町 棚 塩 *1	81 (105)	720	80 (103)	744	80 (94)	720	84 (91)	744	84 (97)	744	81 (95)	720												
30	浪江町 浪 江	155 (167)	720	154 (163)	744	153 (165)	720	156 (164)	740	153 (163)	744	147 (154)	720												
31	浪江町 幾 世 橋	99 (119)	720	98 (112)	744	97 (110)	720	99 (107)	741	99 (109)	744	95 (106)	720												
32	浪江町 大 柿 ダ ム	796 (813)	720	795 (813)	744	801 (830)	720	811 (834)	744	804 (835)	744	784 (814)	714												
33	浪江町 南 津 島	1,170 (1,220)	720	1,170 (1,220)	744	1,160 (1,240)	720	1,160 (1,230)	744	1,120 (1,200)	744	1,080 (1,140)	715												
34	葛尾村 夏 湯	149 (164)	720	148 (160)	744	148 (154)	720	149 (156)	744	148 (161)	744	143 (152)	714												
35	南相馬市 泉 沢	122 (148)	720	120 (134)	744	119 (131)	720	120 (133)	744	121 (137)	744	117 (133)	720												
36	南相馬市 横 川 ダ ム	245 (255)	720	242 (253)	744	242 (254)	720	245 (255)	744	242 (256)	743	236 (246)	720												
37	南相馬市 釐 浜	46 (59)	720	46 (71)	744	45 (55)	720	45 (61)	744	46 (65)	738	45 (65)	720												
38	飯館村 伊 丹 沢	170 (178)	720	167 (188)	744	166 (173)	720	163 (175)	744	162 (189)	739	157 (168)	720												
39	川俣町 山 木 屋	147 (158)	720	142 (160)	744	144 (151)	720	143 (151)	744	140 (157)	738	134 (147)	720												

注) 1 No.の網掛け部分は東京電力ホールディングス株式会社福島第一原子力発電所から半径5km未満の地域

2 *1 可搬型モニタリングポストによる測定

3 *2 空間線量率の測定はモニタリングポスト (NaIシンチレーション検出器、単位：ナノグレイ/時) により行ったが、概ね10,000nGy/h (10μGy/h)を超えた場合は、

併設している高線量用モニタリングポスト (電離箱検出器、単位：ナノグレイ/時) の測定値で補完した。

測定期間 測定項目 測定地点名		H30. 4. 12 ～H30. 7. 5		H30. 7. 5 ～H30. 10. 4		積算線量		測定 日数		積算線量		測定 日数	
		積算線量	測定 日数	積算線量	測定 日数								
No.	測定地点名	積算線量	測定 日数	積算線量	測定 日数	積算線量	測定 日数	積算線量	測定 日数	積算線量	測定 日数	積算線量	測定 日数
1	いわき市 石 森	0.20 (0.21)	84	0.21 (0.21)	91								
2	いわき市 西 倉	0.25 (0.26)	84	0.27 (0.26)	91								
3	いわき市 大 野	0.20 (0.22)	84	0.22 (0.22)	91								
4	いわき市 福 岡	0.22 (0.24)	84	0.24 (0.24)	91								
5	いわき市 大 久	0.21 (0.22)	84	0.23 (0.23)	91								
6	いわき市 末 続	0.27 (0.29)	84	0.29 (0.29)	91								
7	いわき市 上 小川	0.32 (0.34)	84	0.34 (0.34)	91								
8	いわき市 志 田 名	0.35 (0.38)	84	0.37 (0.37)	91								
9	いわき市 小 白 井	0.20 (0.22)	84	0.21 (0.21)	91								
10	田村市 場 々	0.34 (0.37)	84	0.36 (0.36)	91								
11	田村市 古 道	0.24 (0.25)	84	0.25 (0.25)	91								
12	田村市 岩 井 沢	0.19 (0.21)	84	0.21 (0.21)	91								
13	広野町 下 浅見川	0.20 (0.21)	84	0.22 (0.22)	91								
14	広野町 篝 平	0.25 (0.26)	84	0.27 (0.26)	91								
15	楢葉町 山 田 岡	0.21 (0.22)	84	0.22 (0.22)	91								
16	楢葉町 乙 次 郎	0.25 (0.26)	84	0.27 (0.26)	91								
17	楢葉町 井 出	0.27 (0.29)	84	0.30 (0.29)	91								
18	楢葉町 上 繁 岡	0.38 (0.40)	84	0.41 (0.40)	91								
19	富岡町 太 田	0.51 (0.55)	84	0.54 (0.54)	91								
20	富岡町 赤 木	0.42 (0.45)	84	0.46 (0.45)	91								
21	富岡町 小 良 々 浜	3.2 (3.4)	84	3.4 (3.4)	91								
22	富岡町 夜の森北	0.70 (0.75)	84	0.72 (0.71)	91								

(単位 mGy)

(単位 mGy)

(単位 mGy)

測定期間 測定地点名		H30. 4. 12 ～H30. 7. 5		H30. 7. 5 ～H30. 10. 4			
		積算線量	測定 日数	積算線量	測定 日数	積算線量	測定 日数
No.	測定項目						
23	富岡町 上手岡	0. 61 (0. 66)	84	0. 65 (0. 64)	91		
24	川内村 三ツ右	0. 58 (0. 62)	84	0. 61 (0. 61)	91		
25	川内村 貝ノ坂	0. 87 (0. 93)	84	0. 92 (0. 91)	91		
26	川内村 五枚沢	0. 26 (0. 28)	84	0. 28 (0. 27)	91		
27	川内村 上川内	0. 21 (0. 22)	84	0. 22 (0. 22)	91		
28	大熊町 大川原	0. 37 (0. 39)	84	0. 39 (0. 38)	91		
29	大熊町 旭ヶ丘	0. 45 (0. 48)	84	0. 48 (0. 48)	91		
30	大熊町 野上	3. 3 (3. 6)	84	3. 1 (3. 1)	91		
31	大熊町 熊川	6. 7 (7. 2)	84	7. 0 (6. 9)	91		
32	大熊町 大野	8. 3 (8. 9)	84	8. 4 (8. 3)	91		
33	大熊町 夫沢	21 (22)	84	22 (21)	91		
34	大熊町 湯の神	2. 1 (2. 3)	84	2. 2 (2. 2)	91		
35	大熊町 長者原	5. 7 (6. 1)	84	6. 3 (6. 3)	91		
36	双葉町 清戸迫	1. 3 (1. 4)	84	1. 4 (1. 4)	91		
37	双葉町 郡山	0. 88 (0. 94)	84	0. 93 (0. 92)	91		
38	双葉町 長塚	2. 2 (2. 4)	84	1. 4 (1. 3)	91		
39	浪江町 井手	14 (15)	84	15 (15)	91		
40	浪江町 請戸	0. 29 (0. 31)	84	0. 31 (0. 31)	91		
41	浪江町 小野田	1. 0 (1. 1)	84	1. 1 (1. 1)	91		
42	浪江町 幾世橋	0. 31 (0. 33)	84	0. 33 (0. 33)	91		
43	浪江町 刈宿	0. 65 (0. 69)	84	0. 69 (0. 68)	91		
44	浪江町 皇曾根	7. 6 (8. 2)	84	7. 9 (7. 8)	91		

(単位 mGy)

測定期間 測定地点名		H30. 4. 12 ～H30. 7. 5		H30. 7. 5 ～H30. 10. 4			
		積算線量	測定 日数	積算線量	測定 日数	積算線量	測定 日数
No.	測定項目						
45	浪江町 津島	3. 3 (3. 6)	84	3. 4 (3. 4)	91		
46	葛尾村 大天放	0. 39 (0. 42)	84	0. 42 (0. 41)	91		
47	葛尾村 落合	0. 50 (0. 53)	84	0. 53 (0. 52)	91		
48	葛尾村 野行	2. 8 (2. 9)	84	2. 8 (2. 8)	91		
49	南相馬市 浦尻	0. 23 (0. 25)	84	0. 25 (0. 25)	91		
50	南相馬市 耳谷	0. 27 (0. 29)	84	0. 28 (0. 28)	91		
51	南相馬市 川房	1. 1 (1. 1)	84	1. 1 (1. 1)	91		
52	南相馬市 関場	0. 51 (0. 55)	84	0. 54 (0. 54)	91		
53	南相馬市 高	0. 23 (0. 24)	84	0. 24 (0. 24)	91		
54	南相馬市 大木戸	0. 18 (0. 20)	84	0. 19 (0. 19)	91		
55	南相馬市 晝浜	0. 15 (0. 16)	84	0. 16 (0. 16)	91		
56	南相馬市 大原	0. 37 (0. 40)	84	0. 38 (0. 38)	91		
57	南相馬市 川子	0. 25 (0. 27)	84	0. 26 (0. 26)	91		
58	飯館村 蔵平	0. 85 (0. 91)	84	0. 87 (0. 86)	91		
59	飯館村 長泥	3. 3 (3. 6)	84	3. 4 (3. 4)	91		
60	飯館村 飯樋	0. 60 (0. 64)	84	0. 63 (0. 62)	91		
61	飯館村 白石	1. 1 (1. 2)	84	1. 1 (1. 1)	91		
62	飯館村 草野	0. 94 (1. 0)	84	0. 99 (0. 97)	91		
63	川俣町 山木屋坂下	0. 92 (0. 99)	84	0. 96 (0. 95)	91		
64	川俣町 山木屋	0. 33 (0. 35)	84	0. 35 (0. 35)	91		

注) 1 () 内は90日換算値

2 No. の網掛け部分は東京電力ホールディングス株式会社福島第一原子力発電所から半径5km未満の地域

測定地点名 No.		測定年月												
		H30.4				H31.1								
		測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	
1	いわき市 小川	全アルファ 放射能	0.044 (0.26)	684	0.032 (0.15)	732	0.033 (0.21)	636	0.055 (0.27)	744	0.039 (0.18)	708	0.031 (0.11)	714
		全ベータ 放射能	0.068 (0.34)	684	0.054 (0.20)	732	0.055 (0.26)	636	0.081 (0.33)	744	0.062 (0.25)	708	0.052 (0.16)	714
2	田村市 都路馬洗戸	全アルファ 放射能	0.013 (0.10)	720	0.014 (0.10)	744	0.015 (0.066)	660	0.024 (0.095)	744	0.016 (0.077)	732 (0.060)	0.015 (0.060)	708
		全ベータ 放射能	0.034 (0.16)	720	0.037 (0.16)	744	0.037 (0.11)	660	0.048 (0.16)	744	0.038 (0.13)	732	0.036 (0.11)	708
3	広野町 小滝	全アルファ 放射能	0.015 (0.065)	720	0.017 (0.067)	744	0.018 (0.078)	660	0.030 (0.13)	744	0.021 (0.087)	720 (0.067)	0.017 (0.067)	714
		全ベータ 放射能	0.037 (0.11)	720	0.041 (0.12)	744	0.043 (0.13)	660	0.060 (0.22)	744	0.047 (0.14)	720 (0.12)	0.041 (0.12)	714
4	楡葉町 木戸ダム	全アルファ 放射能	0.021 (0.089)	720	0.024 (0.11)	744	0.024 (0.15)	660	0.034 (0.15)	744	0.025 (0.097)	732 (0.069)	0.024 (0.069)	720
		全ベータ 放射能	0.042 (0.13)	720	0.046 (0.15)	744	0.047 (0.20)	660	0.061 (0.21)	744	0.050 (0.14)	732 (0.11)	0.048 (0.11)	720
5	楡葉町 紫の間	全アルファ 放射能	0.020 (0.17)	720	0.023 (0.15)	744	0.029 (0.19)	660	0.048 (0.31)	744	0.027 (0.17)	732 (0.11)	0.018 (0.11)	720
		全ベータ 放射能	0.045 (0.28)	720	0.050 (0.25)	744	0.061 (0.32)	660	0.090 (0.51)	744	0.056 (0.30)	732 (0.18)	0.043 (0.18)	720
6	富岡町 富岡	全アルファ 放射能	0.019 (0.13)	720	0.018 (0.097)	744	0.020 (0.11)	720	0.029 (0.14)	744	0.020 (0.12)	708 (0.066)	0.016 (0.066)	720
		全ベータ 放射能	0.068 (0.38)	720	0.067 (0.29)	744	0.073 (0.34)	720	0.10 (0.44)	744	0.073 (0.37)	708 (0.23)	0.062 (0.23)	720
7	川内村 下川内	全アルファ 放射能	0.028 (0.13)	720	0.031 (0.12)	744	0.032 (0.14)	648	0.042 (0.14)	732	0.031 (0.12)	744 (0.13)	0.031 (0.13)	690
		全ベータ 放射能	0.051 (0.18)	720	0.055 (0.16)	744	0.057 (0.18)	648	0.069 (0.19)	732	0.057 (0.17)	744 (0.21)	0.056 (0.21)	690
8	大熊町 大野	全アルファ 放射能	0.016 (0.091)	720	0.017 (0.088)	744	0.017 (0.099)	720	0.026 (0.11)	744	0.018 (0.093)	684 (0.060)	0.015 (0.060)	720
		全ベータ 放射能	0.067 (0.29)	720	0.070 (0.27)	744	0.070 (0.31)	720	0.096 (0.35)	744	0.073 (0.29)	684 (0.20)	0.063 (0.20)	720

No.	測定地点名	測定項目	H30.4		5		6		7		8		9		10		11		12		H31.1		2		3	
			測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間
9	大瀬町 おとせ町	全アルファ 放射能	0.018 (0.12)	720	0.018 (0.095)	744	0.018 (0.095)	720	0.030 (0.17)	744	0.021 (0.13)	684	0.016 (0.090)	720												
		全ベータ 放射能	0.077 (0.37)	720	0.078 (0.30)	744	0.080 (0.32)	720	0.11 (0.53)	744	0.087 (0.40)	684	0.071 (0.29)	720												
10	双葉町 ふたば町	全アルファ 放射能	0.016 (0.093)	720	0.017 (0.077)	684	0.018 (0.084)	720	0.025 (0.12)	732	0.018 (0.100)	744	0.015 (0.061)	720												
		全ベータ 放射能	0.036 (0.14)	720	0.036 (0.13)	684	0.037 (0.13)	720	0.047 (0.18)	732	0.037 (0.15)	744	0.033 (0.099)	720												
11	浪江町 なげ町	全アルファ 放射能	0.027 (0.15)	720	0.027 (0.16)	744	0.031 (0.14)	660	0.043 (0.29)	744	0.027 (0.14)	744	0.021 (0.088)	720												
		全ベータ 放射能	0.047 (0.20)	720	0.048 (0.22)	744	0.054 (0.19)	660	0.068 (0.37)	744	0.049 (0.19)	744	0.041 (0.13)	720												
12	浪江町 なげ町	全アルファ 放射能	0.033 (0.15)	720	0.030 (0.13)	684	0.034 (0.19)	720	0.054 (0.21)	720	0.034 (0.16)	744	0.035 (0.11)	720												
		全ベータ 放射能	0.075 (0.28)	720	0.071 (0.23)	684	0.077 (0.34)	720	0.11 (0.35)	720	0.078 (0.28)	744	0.079 (0.20)	720												
13	磐尾村 いび村	全アルファ 放射能	0.048 (0.30)	720	0.047 (0.25)	702	0.052 (0.27)	702	0.069 (0.32)	744	0.045 (0.21)	684	0.038 (0.17)	720												
		全ベータ 放射能	0.079 (0.41)	720	0.079 (0.34)	702	0.087 (0.38)	702	0.11 (0.44)	744	0.078 (0.30)	684	0.068 (0.26)	720												
14	南相馬市 なまら市	全アルファ 放射能	0.020 (0.11)	720	0.017 (0.089)	744	0.017 (0.073)	660	0.027 (0.13)	744	0.021 (0.10)	744	0.017 (0.071)	714												
		全ベータ 放射能	0.040 (0.14)	720	0.037 (0.13)	744	0.036 (0.11)	660	0.048 (0.18)	744	0.041 (0.15)	744	0.036 (0.10)	714												
15	南相馬市 なまら市	全アルファ 放射能	0.024 (0.13)	720	0.016 (0.092)	744	0.016 (0.089)	720	0.020 (0.11)	744	0.015 (0.078)	744	0.011 (0.064)	720												
		全ベータ 放射能	0.091 (0.40)	720	0.068 (0.30)	744	0.069 (0.31)	720	0.079 (0.36)	744	0.064 (0.26)	744	0.052 (0.24)	720												
16	飯館村 いづみ村	全アルファ 放射能	0.010 (0.079)	720	0.012 (0.060)	744	0.014 (0.098)	720	0.016 (0.085)	726	0.010 (0.067)	744	0.011 (0.084)	720												
		全ベータ 放射能	0.052 (0.25)	720	0.056 (0.19)	744	0.065 (0.31)	720	0.070 (0.27)	726	0.054 (0.22)	744	0.057 (0.27)	720												
17	川俣町 かわま町	全アルファ 放射能	0.016 (0.086)	720	0.020 (0.14)	744	0.021 (0.12)	708	0.022 (0.14)	744	0.014 (0.10)	732	0.012 (0.064)	720												
		全ベータ 放射能	0.072 (0.28)	720	0.084 (0.39)	744	0.087 (0.38)	708	0.090 (0.44)	744	0.070 (0.32)	732	0.063 (0.22)	720												

注) 1 No.の欄付け部分は京電力ホールディングス株式会社福島第一原子力発電所から半径5km圏の区域

No.	地 点 名	採 取 期 間	核 種 濃 度 (mBq/m ³)									
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce
7	川内村 下川内 (連続ダストモニタ)	H30. 4. 1 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.010	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.008	ND
		H30. 6. 1 ～ H30. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 7. 1 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.005	ND
		H30. 8. 1 ～ H30. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.005	ND
		H30. 9. 1 ～ H30. 10. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.006	ND
8	大熊町 大野 (連続ダストモニタ)	H30. 4. 1 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	0.005	0.043	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	0.006	0.045	ND
		H30. 6. 1 ～ H30. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.022	ND
		H30. 7. 1 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.046	ND
		H30. 8. 1 ～ H30. 9. 1	ND	ND	ND	ND	ND	ND	ND	0.007	0.062	ND
		H30. 9. 1 ～ H30. 10. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.040	ND
9	大熊町 矢沢 (連続ダストモニタ)	H30. 4. 1 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	0.035	0.33	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.098	ND
		H30. 6. 1 ～ H30. 7. 1	ND	ND	ND	ND	ND	ND	ND	0.012	0.11	ND
		H30. 7. 1 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	0.010	0.13	ND
		H30. 8. 1 ～ H30. 9. 1	ND	ND	ND	ND	ND	ND	ND	0.009	0.11	ND
		H30. 9. 1 ～ H30. 10. 1	ND	ND	ND	ND	ND	ND	ND	0.018	0.17	ND
10	双葉町 郡山 (連続ダストモニタ)	H30. 4. 1 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	0.053	0.52	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	0.043	0.43	ND
		H30. 6. 1 ～ H30. 7. 1	ND	ND	ND	ND	ND	ND	ND	0.038	0.38	ND
		H30. 7. 1 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	0.091	0.92	ND
		H30. 8. 1 ～ H30. 9. 1	ND	ND	ND	ND	ND	ND	ND	0.066	0.72	ND
		H30. 9. 1 ～ H30. 10. 1	ND	ND	ND	ND	ND	ND	ND	0.075	0.81	ND
11	浪江町 幾世橋 (連続ダストモニタ)	H30. 4. 1 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.042	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.049	ND
		H30. 6. 1 ～ H30. 7. 1	ND	ND	ND	ND	ND	ND	ND	0.006	0.050	ND
		H30. 7. 1 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.046	ND
		H30. 8. 1 ～ H30. 9. 1	ND	ND	ND	ND	ND	ND	ND	0.006	0.048	ND
		H30. 9. 1 ～ H30. 10. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.053	ND
12	浪江町 大楯ダム (連続ダストモニタ)	H30. 4. 1 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	0.011	0.094	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	0.010	0.10	ND
		H30. 6. 1 ～ H30. 7. 1	ND	ND	ND	ND	ND	ND	ND	0.005	0.039	ND
		H30. 7. 1 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	0.011	0.12	ND
		H30. 8. 1 ～ H30. 9. 1	ND	ND	ND	ND	ND	ND	ND	0.007	0.080	ND
		H30. 9. 1 ～ H30. 10. 1	ND	ND	ND	ND	ND	ND	ND	0.011	0.089	ND

[illegible]

[illegible]

No.	地 点 名	採 取 期 間	核 種 濃 度 (mBq/m ³)									
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce
37	田村市 船 引 (簡易型ダスト サンプラー)	H30. 4. 2 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.019	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 6. 1 ～ H30. 7. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 7. 2 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 8. 1 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 9. 3 ～ H30.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.015	ND
38	田村市 上 移 (簡易型ダスト サンプラー)	H30. 4. 2 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 6. 1 ～ H30. 7. 2	ND	ND	ND	ND	ND	ND	ND	ND	0.016	ND
		H30. 7. 2 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.016	ND
		H30. 8. 1 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 9. 3 ～ H30.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.027	ND
39	川内村 上 川 内 (簡易型ダスト サンプラー)	H30. 4. 2 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.014	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.011	ND
		H30. 6. 1 ～ H30. 7. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 7. 2 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.019	ND
		H30. 8. 1 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 9. 3 ～ H30.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.021	ND
40	南相馬市 馬 場 (簡易型ダスト サンプラー)	H30. 4. 2 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.064	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.073	ND
		H30. 6. 1 ～ H30. 7. 2	ND	ND	ND	ND	ND	ND	ND	ND	0.068	ND
		H30. 7. 2 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.10	ND
		H30. 8. 1 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	0.098	ND
		H30. 9. 3 ～ H30.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.17	ND
41	南相馬市 大 戸 (簡易型ダスト サンプラー)	H30. 4. 2 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.064	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.065	ND
		H30. 6. 1 ～ H30. 7. 2	ND	ND	ND	ND	ND	ND	ND	ND	0.051	ND
		H30. 7. 2 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.070	ND
		H30. 8. 1 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	0.085	ND
		H30. 9. 3 ～ H30.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.098	ND
42	南相馬市 檀 原 (簡易型ダスト サンプラー)	H30. 4. 2 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.12	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.033	ND
		H30. 6. 1 ～ H30. 7. 2	ND	ND	ND	ND	ND	ND	ND	ND	0.035	ND
		H30. 7. 2 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.049	ND
		H30. 8. 1 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	0.051	ND
		H30. 9. 3 ～ H30.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	0.058	ND

(注) 1 No. の網掛け部分は東京電力ホールディングス株式会社福島第一原子力発電所から半径5km未満の地域

2 「ND」：検出限界未満

3 上記の他、人工放射性核種は検出されなかった。

4 ¹³⁴Cs及び¹³⁷Csの検出限界値：連続ダストモニタはおおむね0.01 mBq/m³以下、リアルタイムダストモニタはおおむね0.06 mBq/m³以下、ダストサンプラーはおおむね0.1 mBq/m³以下、簡易型ダストサンプラーはおおむね0.03 mBq/m³以下、簡易型ダストサンプラー（1日集じん）はおおむね0.05 mBq/m³以下である。

5-2-3 大気中水分のトリチウム濃度

No.	地 点 名	採 取 期 間	トリチウム濃度		備考
			大気中濃度 (mBq/m ³)	(参考値) 捕集水濃度 (Bq/l)	
1	檜 葉 町 繁 岡	H30. 4. 4 ～ H30. 5. 1	6. 0	0. 69	8. 7
		H30. 5. 1 ～ H30. 6. 1	9. 1	0. 84	11
		H30. 6. 1 ～ H30. 7. 2	ND	ND	14
		H30. 7. 2 ～ H30. 8. 1	ND	ND	18
		H30. 8. 1 ～ H30. 9. 3	ND	ND	18
		H30. 9. 3 ～ H30. 10. 1	7. 2	0. 49	15
2	富 岡 町 富 岡	H30. 4. 5 ～ H30. 5. 1	6. 5	0. 78	8. 3
		H30. 5. 1 ～ H30. 6. 1	10	0. 96	11
		H30. 6. 1 ～ H30. 7. 2	3. 6	0. 57	6. 3
		H30. 7. 2 ～ H30. 8. 1	ND	ND	21
		H30. 8. 1 ～ H30. 9. 3	ND	ND	20
		H30. 9. 3 ～ H30. 10. 1	9. 7	0. 55	18
3	大 熊 町 大 野	H30. 4. 4 ～ H30. 5. 1	7. 0	0. 87	8. 0
		H30. 5. 1 ～ H30. 6. 1	12	1. 1	11
		H30. 6. 1 ～ H30. 7. 2	9. 4	1. 2	8. 2
		H30. 7. 2 ～ H30. 8. 1	13	0. 66	20
		H30. 8. 1 ～ H30. 9. 3	9. 9	0. 49	20
		H30. 9. 3 ～ H30. 10. 1	13	0. 75	17
4	大 熊 町 矢 沢	H30. 4. 4 ～ H30. 5. 1	51	5. 9	8. 6
		H30. 5. 1 ～ H30. 6. 1	64	5. 4	12
		H30. 6. 1 ～ H30. 7. 2	48	3. 4	14
		H30. 7. 2 ～ H30. 8. 1	41	2. 6	16
		H30. 8. 1 ～ H30. 9. 3	51	2. 8	19
		H30. 9. 3 ～ H30. 10. 1	62	3. 9	16
5	双 葉 町 郡 山	H30. 4. 4 ～ H30. 5. 1	36	4. 2	8. 6
		H30. 5. 1 ～ H30. 6. 1	56	4. 7	12
		H30. 6. 1 ～ H30. 7. 2	54	3. 5	15
		H30. 7. 2 ～ H30. 8. 1	49	2. 3	21
		H30. 8. 1 ～ H30. 9. 3	53	2. 4	22
		H30. 9. 3 ～ H30. 10. 1	38	2. 1	18

(注) 1 No. の網掛け部分は東京電力ホールディングス株式会社福島第一原子力発電所から半径5km未満の地域

2 「ND」：検出限界未満

3 検出限界値はおおむね5mBq/m³以下

5-2-4 降下物の核種濃度

No.	地 点 名	採 取 期 間	核 種 濃 度 (Bq/m ² (MBq/km ²))												
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹²⁵ Sb	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce	
1	いわき市 ひまのはま 久之浜	H30. 4. 3 ～ H30. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.56	5.1	ND
		H30. 5. 2 ～ H30. 6. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.22	2.3	ND
		H30. 6. 4 ～ H30. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.088	0.89	ND
		H30. 7. 3 ～ H30. 8. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.13	1.1	ND
		H30. 8. 2 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.095	1.4	ND
2	田村市 みやこじ 都 路	H30. 9. 3 ～ H30. 10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.073	0.86	ND
		H30. 4. 3 ～ H30. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.3	12	ND
		H30. 5. 2 ～ H30. 6. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.34	3.4	ND
		H30. 6. 4 ～ H30. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.24	2.4	ND
		H30. 7. 3 ～ H30. 8. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.52	4.2	ND
3	富岡町 とみおか 富 岡	H30. 8. 2 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.6	15	ND
		H30. 9. 3 ～ H30. 10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.9	50	ND
		H30. 4. 2 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.6	14	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.79	7.3	ND
		H30. 6. 1 ～ H30. 7. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.59	5.3	ND
4	大熊町 おおの 大 野	H30. 7. 2 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.74	6.4	ND
		H30. 8. 1 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.70	6.8	ND
		H30. 9. 3 ～ H30. 10. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.98	10	ND
		H30. 4. 2 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	15	130	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.8	54	ND
5	双葉町 ふたば 郡 山	H30. 6. 1 ～ H30. 7. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.1	30	ND
		H30. 7. 2 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.9	18	ND
		H30. 8. 1 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.8	78	ND
		H30. 9. 3 ～ H30. 10. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.8	70	ND
		H30. 4. 2 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	16	160	ND
6	南相馬市 かいば 亶 浜	H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	8.5	79	ND
		H30. 6. 1 ～ H30. 7. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	12	110	ND
		H30. 7. 2 ～ H30. 8. 1	ND	ND	ND	ND	0.21	ND	ND	ND	ND	ND	15	150	ND
		H30. 8. 1 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	13	130	ND
		H30. 9. 3 ～ H30. 10. 1	ND	ND	ND	ND	0.21	ND	ND	ND	ND	2.0	120	1,300	ND
		H30. 4. 2 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.96	8.4	ND
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.56	4.9	ND
		H30. 6. 1 ～ H30. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.26	2.8	ND
		H30. 7. 3 ～ H30. 8. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.27	2.6	ND
		H30. 8. 2 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.23	1.9	ND
		H30. 9. 3 ～ H30. 10. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.54	4.9	ND	

No.	地 点 名	採 取 期 間	核 種 濃 度 (Bq/m ² (MBq/km ²))											
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹²⁵ Sb	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce
7	浪江町 なみえ 浪江	H30. 4. 3 ～ H30. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.5	14	ND
		H30. 5. 2 ～ H30. 6. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.1	19	ND
		H30. 6. 4 ～ H30. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.81	8.8	ND
		H30. 7. 3 ～ H30. 8. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.66	5.0	ND
		H30. 8. 2 ～ H30. 9. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.1	11	ND
		H30. 9. 4 ～ H30. 10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.6	74	ND
8	浪江町 つしま 津島	H30. 4. 3 ～ H30. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.4	31	ND
		H30. 5. 2 ～ H30. 6. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.9	61	ND
		H30. 6. 4 ～ H30. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.3	33	ND
		H30. 7. 3 ～ H30. 8. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.8	46	ND
		H30. 8. 2 ～ H30. 9. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.4	55	ND
		H30. 9. 4 ～ H30. 10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.9	53	ND
9	葛尾村 かしわばら 柏原	H30. 4. 3 ～ H30. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.8	23	ND
		H30. 5. 2 ～ H30. 6. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.4	48	ND
		H30. 6. 4 ～ H30. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.5	32	ND
		H30. 7. 3 ～ H30. 8. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.2	8.8	ND
		H30. 8. 2 ～ H30. 9. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.0	61	ND
		H30. 9. 4 ～ H30. 10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.3	25	ND
10	川俣町 やまぎ 山木屋	H30. 4. 3 ～ H30. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.7	13	ND
		H30. 5. 2 ～ H30. 6. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.9	15	ND
		H30. 6. 4 ～ H30. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.8	16	ND
		H30. 7. 3 ～ H30. 8. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.8	19	ND
		H30. 8. 2 ～ H30. 9. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.4	22	ND
		H30. 9. 4 ～ H30. 10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8	39	ND

(注) 1 No. の網掛け部分は東京電力ホールディングス株式会社福島第一原子力発電所から半径5km未満の地域

2 「ND」：検出限界未満

5-2-5 環境試料中の核種濃度

試料名	種類 又は 部位	採取 年月日	採取地点 及C採取地点名	単位	全 ^{α+β} 放射能 濃度	核 種 濃 度																天然 核種			
						⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁶ Nb	¹⁰⁰ Ru	¹²⁵ Sb	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce	³ H	¹³¹ I	⁸⁶ Sr	⁹⁰ Sr	²³⁸⁺²⁴⁰ Pu	²³⁹⁺²⁴⁰ Pu	²⁴¹ Am	²⁴¹ Am
土 壌	土 壤			Bq/kg乾	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	730	
			/												/	/	/	/	/	/	/	/			
		1 いわき市 久之浜	H30. 5.21		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	730
					/											/	/	/	/	/	/	/	/		
		2 田村市 古道	H30. 5.16		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	45	440	ND	/	/	0.24	ND	ND	ND	ND	860
					/											/	/	/	/	/	/	/	/		
		3 広野町 下北追	H30. 5.21		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	51	500	ND	/	/	0.74	ND	0.03	0.01	ND	720
					/											/	/	/	/	/	/	/	/		
		4 檜葉町 波倉	H30. 5.21		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	11	120	ND	/	/	0.22	ND	ND	ND	ND	910
					/											/	/	/	/	/	/	/	/		
		5 富岡町 小浜	H30. 5.14		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	9.3	87	ND	/	/	0.23	ND	ND	ND	ND	280
					/											/	/	/	/	/	/	/	/		
		6 川内村 上川内	H30. 5.16		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	53	510	ND	/	/	0.89	ND	ND	ND	ND	1,100
					/											/	/	/	/	/	/	/	/		
		7 大熊町 矢沢	H30. 5.11		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	23,000	220,000	ND	/	/	24	ND	0.07	0.02	ND	650
		/											/	/	/	/	/	/	/	/					
8 双葉町 都山	H30. 5.11	/	ND	ND	ND	ND	5.3	ND	ND	ND	130	4,200	41,000	ND	/	/	57	0.06	0.37	0.14	0.02	520			
		/											/	/	/	/	/	/	/	/					
9 浪江町 北幾世橋	H30. 5.28	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	96	940	ND	/	/	2.6	ND	0.35	0.12	ND	530			
		/											/	/	/	/	/	/	/	/					
10 越尾村 相原	H30. 5.16	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	2,000	19,000	ND	/	/	3.7	ND	0.02	ND	ND	860			
		/											/	/	/	/	/	/	/	/					
11 南相馬市 蒲尻	H30. 5.14	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	110	1,200	ND	/	/	1.5	ND	0.23	0.09	ND	400			
		/											/	/	/	/	/	/	/	/					
12 南相馬市 馬場	H30. 5.14	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	710	6,700	ND	/	/	3.7	ND	0.02	ND	ND	660			
		/											/	/	/	/	/	/	/	/					
13 飯館村 蔵平	H30. 5.7	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	230	2,200	ND	/	/	1.3	ND	0.02	ND	ND	830			
		/											/	/	/	/	/	/	/	/					
14 飯館村 長泥	H30. 5.7	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	2,300	22,000	ND	/	/	4.5	0.01	0.02	ND	ND	860			
		/											/	/	/	/	/	/	/	/					
15 川俣町 山本屋	H30. 5.7	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	1,600	15,000	ND	/	/	3.5	0.04	0.16	0.02	ND	730			
		/											/	/	/	/	/	/	/	/					

試料名	種類 又は 部位	採取 年月日	採取地点番号 及び採取地点名	単位	全ベータ 放射能 濃度	核 種 濃 度														天然 核種					
						⁵¹ Cr	⁵⁵ Mn	⁵⁹ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁰ Zr	⁹⁶ Nb	¹⁰⁰ Ru	¹³⁵ Cs	¹³⁷ Cs	¹⁴⁴ Cs	¹⁴⁷ Sm	¹³¹ I	⁸⁹ Sr	⁹⁰ Sr	²³⁸ U	^{239/240} Pu	²⁴¹ Am	²⁴¹ Cm	⁴⁰ K
上 水	蛇口水	1	いわき市	Bq/ℓ Puは mBq/ℓ	／	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.046		
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.062
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.055
		2	田村市			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.026
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		3	広野町			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		4	楢葉町			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		5	富岡町			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		6	川内村			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
7	大熊町 *1	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—				
		—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—				
8	双葉町 *1	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—				
		—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—				
9	浪江町	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
10	葛尾村	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
11	南相馬市	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
12	飯館村	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
13	川俣町	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
海 水	表面水	1	第一(独)南放水口付近	Bq/ℓ Puは mBq/ℓ	／	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		2	第一(独)北放水口付近			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		3	第一(独)北放水口付近			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		4	第一(独)北放水口付近			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		5	第一(独)北放水口付近			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		6	第一(独)北放水口付近			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
						ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
7	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
8	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
9	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
10	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
11	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
12	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
13	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
14	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
15	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
16	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
17	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
18	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
19	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
20	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
21	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
22	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
23	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
24	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
25	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
26	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
27	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
28	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
29	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
30	第一(独)北放水口付近	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		ND	ND	ND	ND	ND	ND	ND	ND	ND															

試料名	種類 又は 部位	採取 年月日	採取地点番号 及び採取地点名	単位	全γ線 放射能 濃度	核 種 濃 度														天然 核種				
						⁵¹ Cr	⁵⁴ Mn	⁵⁹ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁰ Zr	⁹³ Nb	¹⁰¹ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Co	³ H	¹²⁷ I	⁹⁰ Sr	^{238/239} Pu	²⁴¹ Am	²⁴¹ Cm	⁴⁰ K	
海 水	表面水	3	第一(発)取水口付近 (港湾出入口の外側)	H30. 4. 20	0.02	/	ND	ND	ND	ND	ND	ND	ND	ND	0.010	ND	ND	/	ND	ND	/	/	/	
				H30. 5. 16	0.02	/	ND	ND	ND	ND	ND	ND	0.008	0.086	ND	ND	/	0.013	ND	ND	/	/	/	
				H30. 6. 14	0.03	/	ND	ND	ND	ND	ND	ND	0.008	0.071	ND	ND	/	0.010	ND	0.007	/	/	/	
		4	第一(発)沖合2km	H30. 7. 10	0.02	/	ND	ND	ND	ND	ND	ND	ND	ND	0.007	ND	ND	/	0.0008	ND	ND	/	/	
				H30. 8. 19	0.03	/	ND	ND	ND	ND	ND	ND	0.003	0.045	ND	ND	/	0.0012	ND	ND	/	/	/	
				H30. 9. 13	0.03	/	ND	ND	ND	ND	ND	ND	0.031	0.34	ND	0.66	/	0.013	ND	0.008	/	/	/	
		4	第一(発)沖合2km	H30. 4. 20	ND	/	ND	ND	ND	ND	ND	ND	ND	ND	0.008	ND	ND	/	0.0006	ND	ND	/	/	
				H30. 5. 16	0.03	/	ND	ND	ND	ND	ND	ND	ND	0.019	ND	ND	/	0.0015	ND	0.007	/	/	/	
				H30. 6. 14	0.02	/	ND	ND	ND	ND	ND	ND	ND	0.011	ND	ND	/	0.0007	ND	ND	/	/	/	
		5	夫沢・熊川沖2km (大熊町)	H30. 7. 10	0.02	/	ND	ND	ND	ND	ND	ND	ND	ND	0.004	ND	ND	/	0.0011	ND	0.007	/	/	
				H30. 8. 19	0.03	/	ND	ND	ND	ND	ND	ND	ND	0.007	ND	ND	/	0.0010	ND	ND	/	/	/	
				H30. 9. 13	ND	/	ND	ND	ND	ND	ND	ND	ND	0.012	ND	ND	/	0.0009	ND	ND	/	/	/	
		6	双葉・熊田川沖2km (双葉町)	H30. 4. 20	0.02	/	ND	ND	ND	ND	ND	ND	ND	ND	0.014	ND	ND	/	0.0009	ND	0.007	/	/	
				H30. 5. 16	0.02	/	ND	ND	ND	ND	ND	ND	ND	0.009	ND	ND	/	0.0011	ND	ND	/	/	/	
				H30. 6. 14	0.02	/	ND	ND	ND	ND	ND	ND	ND	0.007	ND	ND	/	0.0007	ND	0.005	/	/	/	
7	第二(発)南放水口	H30. 7. 10	0.02	/	ND	ND	ND	ND	ND	ND	ND	ND	0.008	ND	ND	/	0.0010	ND	ND	/	/			
		H30. 8. 19	0.02	/	ND	ND	ND	ND	ND	ND	ND	0.007	ND	ND	/	0.0010	ND	ND	/	/	/			
		H30. 9. 13	ND	/	ND	ND	ND	ND	ND	ND	ND	0.012	ND	ND	/	0.0012	ND	ND	/	/	/			
8	第二(発)北放水口	H30. 4. 20	0.02	/	ND	ND	ND	ND	ND	ND	ND	ND	0.005	ND	ND	/	ND	ND	0.007	/	/			
		H30. 5. 16	0.02	/	ND	ND	ND	ND	ND	ND	ND	0.006	ND	ND	/	0.0010	ND	ND	0.007	/	/			
		H30. 6. 14	0.02	/	ND	ND	ND	ND	ND	ND	ND	0.010	ND	ND	/	0.0008	ND	ND	/	/	/			
海底土	海底土	1	第一(発)北放水口付近	H30. 7. 10	0.03	/	ND	ND	ND	ND	ND	ND	ND	0.005	ND	ND	/	0.0006	ND	ND	/	/		
				H30. 8. 19	ND	/	ND	ND	ND	ND	ND	ND	ND	0.006	ND	ND	/	0.0007	ND	ND	/	/		
				H30. 9. 13	0.02	/	ND	ND	ND	ND	ND	ND	ND	0.019	ND	ND	/	0.0016	ND	ND	/	/		
		2	第一(発)南放水口	H30. 5. 22	0.01	/	ND	ND	ND	ND	ND	ND	ND	ND	0.028	ND	ND	/	0.0008	ND	0.009	/	/	
				H30. 9. 6	0.02	/	ND	ND	ND	ND	ND	ND	0.003	0.023	ND	ND	/	/	/	/	/	/	/	
				H30. 5. 22	0.01	/	ND	ND	ND	ND	ND	ND	ND	0.003	0.035	ND	ND	/	0.0011	ND	0.011	/	/	/
		3	第一(発)北放水口	H30. 4. 20	0.02	/	ND	ND	ND	ND	ND	ND	ND	ND	0.023	ND	ND	/	/	/	/	/	/	
				H30. 5. 16	/	ND	ND	ND	ND	ND	ND	ND	25	230	ND	/	/	0.20	ND	0.43	/	/	440	
				H30. 8. 19	/	ND	ND	ND	ND	ND	ND	ND	27	280	ND	/	/	0.26	ND	0.14	/	/	540	
		4	第一(発)北放水口付近	H30. 5. 16	/	ND	ND	ND	ND	ND	ND	ND	ND	30	280	ND	/	/	0.22	ND	0.39	/	/	500
				H30. 8. 19	/	ND	ND	ND	ND	ND	ND	ND	14	140	ND	/	/	ND	ND	0.15	/	/	470	
				H30. 5. 16	/	ND	ND	ND	ND	ND	ND	ND	38	360	ND	/	/	ND	ND	0.36	/	/	580	
		5	第一(発)取水口付近 (港湾出入口の外側)	H30. 8. 19	/	ND	ND	ND	ND	ND	ND	ND	38	400	ND	/	/	0.31	ND	0.34	/	/	550	
				H30. 5. 16	/	ND	ND	ND	ND	ND	ND	ND	3.4	32	ND	/	/	ND	ND	0.41	/	/	500	
				H30. 8. 19	/	ND	ND	ND	ND	ND	ND	ND	3.5	43	ND	/	/	ND	ND	0.39	/	/	480	
6	双葉・熊田川沖2km (双葉町)	H30. 5. 16	/	ND	ND	ND	ND	ND	ND	ND	3.6	34	ND	/	/	ND	ND	0.21	/	/	480			
		H30. 8. 19	/	ND	ND	ND	ND	ND	ND	ND	2.8	31	ND	/	/	0.21	ND	0.39	/	/	500			
		H30. 5. 16	/	ND	ND	ND	ND	ND	ND	ND	3.5	40	ND	/	/	ND	ND	0.46	/	/	490			
7	第二(発)南放水口	H30. 8. 19	/	ND	ND	ND	ND	ND	ND	ND	2.3	22	ND	/	/	ND	ND	0.35	/	/	420			
		H30. 5. 22	/	ND	ND	ND	ND	ND	ND	ND	10	100	ND	/	/	ND	ND	0.23	/	/	500			
		H30. 9. 6	/	ND	ND	ND	ND	ND	ND	ND	11	110	ND	/	/	/	/	/	/	/	560			
8	第二(発)北放水口	H30. 5. 22	/	ND	ND	ND	ND	ND	ND	ND	6.3	60	ND	/	/	ND	ND	0.21	/	/	430			
		H30. 9. 6	/	ND	ND	ND	ND	ND	ND	ND	7.7	78	ND	/	/	/	/	/	/	/	500			

飲料名	種類 又は 部位	採取 年月日	採取地点番号 及び採取地点名	単位	全γ線 放射能 濃度	核 種 濃 度																天然 核種
						⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁰ Zr	⁹³ Nb	¹⁰⁰ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Co	³ H	¹²⁷ I	⁸⁶ Sr	⁹⁰ Sr	^{238/240} Pu	
松 葉	二年葉	1	いわき市 久之浜 ひさのこまき くのしな	Bq/kg生	/	ND	ND	ND	ND	ND	ND	ND	1.8	17	ND	/	/	/	/	/	89	
		/			ND	ND	ND	ND	ND	ND	ND	1.7	ND	/	/	/	/	/	/	65		
		2			田村市 古道 ふるみち	/	ND	ND	ND	ND	ND	ND	1.3	ND	/	ND	/	/	/	/	91	
		/	ND		ND	ND	ND	ND	ND	ND	ND	1.2	ND	/	ND	/	/	/	/	91		
		3	広野町 上北迫 ひろの きたしほ		/	ND	ND	ND	ND	ND	ND	ND	5.4	ND	/	ND	/	/	/	/	69	
		/	ND		ND	ND	ND	ND	ND	ND	ND	3.4	ND	/	ND	/	/	/	/	/	74	
		4	楢葉町 波倉 ならは なるくら		/	ND	ND	ND	ND	ND	ND	7.9	75	ND	/	ND	/	/	/	/	100	
		/	ND		ND	ND	ND	ND	ND	ND	14	140	ND	/	ND	/	/	/	/	/	72	
		5	富岡町 小浜 とみおか		/	ND	ND	ND	ND	ND	ND	ND	3.5	35	ND	/	ND	/	/	/	/	62
		/	ND		ND	ND	ND	ND	ND	ND	2.0	20	ND	/	ND	/	/	/	/	/	73	
		6	川内村 上川内 かわうち かわうち		/	ND	ND	ND	ND	ND	ND	ND	1.2	ND	/	ND	/	/	/	/	/	70
		/	ND		ND	ND	ND	ND	ND	ND	0.79	ND	ND	/	ND	/	/	/	/	/	89	
		7	大熊町 美沢 おほくま		/	ND	ND	ND	ND	ND	ND	75	720	ND	/	ND	/	/	/	/	/	63
		/	ND		ND	ND	ND	ND	ND	ND	30	310	ND	/	ND	/	/	/	/	/	/	53
		8	大熊町 大川原 おほくま だいかわら		/	ND	ND	ND	ND	ND	ND	19	180	ND	/	ND	/	/	/	/	/	83
/	ND	ND	ND		ND	ND	ND	ND	9.1	96	ND	/	ND	/	/	/	/	/	/	73		
9	双葉町 都山 ふたば ともやま	/	ND		ND	ND	ND	ND	ND	14	130	ND	/	ND	/	/	/	/	/	45		
/	ND	ND	ND		ND	ND	ND	ND	13	130	ND	/	ND	/	/	/	/	/	/	38		
10	浪江町 北幾世橋 なげ きたよせはし	/	ND		ND	ND	ND	ND	ND	0.63	7.0	ND	/	ND	/	/	/	/	/	110		
/	ND	ND	ND		ND	ND	ND	ND	0.69	6.6	ND	/	ND	/	/	/	/	/	/	120		
11	越尾村 相原 えし さいはら	/	ND		ND	ND	ND	ND	ND	2.4	22	ND	/	ND	/	/	/	/	/	81		
/	ND	ND	ND		ND	ND	ND	ND	0.90	11	ND	/	ND	/	/	/	/	/	/	77		
12	南相馬市 蒲尻 みなま かんざし	/	ND		ND	ND	ND	ND	ND	0.64	4.9	ND	/	ND	/	/	/	/	/	58		
/	ND	ND	ND		ND	ND	ND	ND	ND	5.0	ND	/	ND	/	/	/	/	/	/	69		
13	飯館村 蔵平 いづみ くらへい	/	ND		ND	ND	ND	ND	ND	19	190	ND	/	ND	/	/	/	/	/	73		
/	ND	ND	ND		ND	ND	ND	ND	10	100	ND	/	ND	/	/	/	/	/	/	89		
14	飯館村 長堤 いづみ ながて	/	ND		ND	ND	ND	ND	ND	2.9	27	ND	/	ND	/	/	/	/	/	66		
/	ND	ND	ND		ND	ND	ND	ND	3.5	35	ND	/	ND	/	/	/	/	/	/	99		
15	川俣町 山木屋 かわま さんぎや	/	ND		ND	ND	ND	ND	ND	0.79	7.7	ND	/	ND	/	/	/	/	/	65		
/	ND	ND	ND		ND	ND	ND	ND	0.89	8.1	ND	/	ND	/	/	/	/	/	/	65		

(注) 1 土壌及び松葉のNo.の欄掛け部分は東京電力ホールデルディングス株式会社福島第一原子力発電所から半径5km未満の地域、海水及び堆底土のNo.の欄掛け部分は東京電力ホールデルディングス株式会社福島第一原子力発電所の放排水口付近

2 「ND」：検出限界未満 「/」：対象外核種 「-」：欠測

3 第一(発)：東京電力ホールデルディングス株式会社福島第一原子力発電所 第二(発)：東京電力ホールデルディングス株式会社福島第二原子力発電所

4 上記の他、人工放射性核種は検出されなかった。

5 *1 水道未復旧のため試料を採取できず、欠測となった。

5-3 比較对照地点

5-3-1 空間線量率 (比較対照地点)

單位線量率:nGy/h 測定時間:h
上段:平均值(下段):最大值

測定年月		測定項目																							
		H30.4		5		6		7		8		9		10		11		12		H31.1		2		3	
No.	測定地点名	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間
1	福島市 （高さ2.5mの測定値）	108 (118)	720	106 (119)	744	107 (114)	720	106 (117)	736	107 (119)	744	105 (116)	720	107 (119)	744	105 (116)	720	107 (119)	744	105 (116)	720	107 (119)	744	105 (116)	720
	福島市 （高さ1mの測定値）	117 (125)	720	115 (128)	744	117 (125)	720	116 (124)	737	116 (125)	744	112 (120)	720	116 (125)	744	112 (120)	720	116 (125)	744	112 (120)	720	116 (125)	744	112 (120)	720
2	郡山市 白 田	133 (146)	720	132 (152)	744	134 (140)	720	134 (140)	739	133 (148)	744	129 (151)	720	133 (148)	744	129 (151)	720	133 (148)	744	129 (151)	720	133 (148)	744	129 (151)	720
3	いわき市 草	63 (75)	720	63 (76)	744	62 (68)	720	62 (73)	739	63 (82)	744	63 (72)	720	63 (82)	744	63 (72)	720	63 (82)	744	63 (72)	720	63 (82)	744	63 (72)	720

5-3-2 大気浮遊じんの核種濃度（比較対照地点）

No.	地 点 名	採 取 期 間	核 種 濃 度 (mBq/m ³)									
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs
1	福島市 方 田 （簡易型ダスト サンプル）	H30.4. 3 ～ H30.4. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.056
		H30.5. 15 ～ H30.5. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.6. 4 ～ H30.6. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.037
		H30.7. 5 ～ H30.7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.036
		H30.8. 14 ～ H30.8. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.9. 6 ～ H30.9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
2	会津若松市 追 手 町 （簡易型ダスト サンプル）	H30.4. 5 ～ H30.4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.5. 14 ～ H30.5. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.6. 5 ～ H30.6. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.7. 3 ～ H30.7. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.8. 1 ～ H30.8. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.9. 10 ～ H30.9. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
3	郡山市 麓 山 （簡易型ダスト サンプル）	H30.4. 11 ～ H30.4. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.5. 21 ～ H30.5. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.040
		H30.6. 13 ～ H30.6. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.7. 9 ～ H30.7. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.8. 13 ～ H30.8. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.9. 20 ～ H30.9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
4	白河市 昭和町 （簡易型ダスト サンプル）	H30.4. 5 ～ H30.4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.030
		H30.5. 14 ～ H30.5. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.6. 5 ～ H30.6. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.7. 3 ～ H30.7. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.8. 1 ～ H30.8. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.9. 10 ～ H30.9. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
5	相馬市 玉 野 （簡易型ダスト サンプル）	H30.4. 9 ～ H30.4. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.5. 16 ～ H30.5. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.059
		H30.6. 7 ～ H30.6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.7. 5 ～ H30.7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.8. 6 ～ H30.8. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.9. 18 ～ H30.9. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
6	伊達市 富 成 （簡易型ダスト サンプル）	H30.4. 9 ～ H30.4. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.5. 16 ～ H30.5. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.034
		H30.6. 7 ～ H30.6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.7. 5 ～ H30.7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.8. 6 ～ H30.8. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.9. 18 ～ H30.9. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
7	南会津町 田 島 （簡易型ダスト サンプル）	H30.4. 5 ～ H30.4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.5. 14 ～ H30.5. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.6. 5 ～ H30.6. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.7. 3 ～ H30.7. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.8. 1 ～ H30.8. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.9. 10 ～ H30.9. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

（注） 1 「ND」：検出限界未満 「-」：欠測

2 上記の他、人工放射性核種は検出されなかった。

3 ろ紙の底化処理はせず、ろ紙を直接はろ器で測定した。

4 ¹³⁴Cs及び¹³⁷Csの検出限界値：簡易型ダストサンプラナー（1週間集じん）はおおむね0.04 mBq/m3以下である。

5-3-3 大気中水分のトリチウム濃度 (比較対照地点)

No.	地 点 名	採 取 期 間	トリチウム濃度		備考
			大気中濃度 (mBq/m ³)	(参考値) 捕集水濃度 (Bq/l)	
1	福 島 市 方 木 田 ^{ほうきだ}	H30. 4. 2 ～ H30. 5. 1	5. 8	0. 75	大気中水分量 (g /m ³) 7. 8
		H30. 5. 1 ～ H30. 6. 1	7. 4	0. 76	9. 8
		H30. 6. 1 ～ H30. 7. 2	6. 3	0. 47	13
		H30. 7. 2 ～ H30. 8. 1	ND	ND	19
		H30. 8. 1 ～ H30. 9. 3	8. 3	0. 45	18
		H30. 9. 3 ～ H30. 10. 1	6. 9	0. 46	15

(注) 「ND」：検出限界未満

数値は有効数字 2 桁にて表記

5-3-4 降下物の核種濃度 (比較対照地点)

No.	地 点 名	採 取 期 間	核 種 濃 度 (Bq/m ² (MBq/km ²))											
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce	
1	福島市 ふくしま 方木田	H30. 4. 2 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	1. 8	16	ND	
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	1. 3	13	ND	
		H30. 6. 1 ～ H30. 7. 2	ND	ND	ND	ND	ND	ND	ND	ND	0. 63	6. 1	ND	
		H30. 7. 2 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	0. 58	5. 7	ND	
		H30. 8. 1 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	0. 49	5. 2	ND	
		H30. 9. 3 ～ H30.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	0. 57	5. 8	ND	
2	三春町 さんしゅ 深 作	H30. 4. 2 ～ H30. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	0. 18	1. 7	ND	
		H30. 5. 1 ～ H30. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	0. 099	0. 78	ND	
		H30. 6. 1 ～ H30. 7. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 23	ND	
		H30. 7. 2 ～ H30. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 21	ND	
		H30. 8. 1 ～ H30. 9. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 35	ND	
		H30. 9. 3 ～ H30.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 73	ND	

(注) 1 「ND」：検出限界未満 「／」：対象外核種
2 上記の他、人工放射性核種は検出されなかった。

5-3-5 環境試料中の核種濃度（比較対照地点）

試料名	種類 又は 部位	採取地点番号 及び採取地点名	採取 年月日	単位	全 ^{α・β} 放射能 濃度	核 種													濃 度	天然 核種						
						⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹²⁵ Sb	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce	³ H			¹³¹ I	⁹⁰ Sr	²³⁸ Pu	²³⁹⁺²⁴⁰ Pu	²⁴¹ Am	²⁴⁴ Cm
土 壌	土 壌	1 福島市 荒井	H30. 5. 30	Bq/kg乾	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	67	650	ND	/	/	/	1.1	ND	0.24	0.06	ND	350
		2 郡山市 蓬瀬町	H30. 5. 28		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	190	1,800	ND	/	/	/	0.62	ND	0.02	/	400
		3 いわき市 川部町	H30. 5. 25		/	ND	ND	ND	ND	ND	ND	ND	ND	20	250	2,300	ND	/	/	/	7.1	ND	0.18	/	310	
		4 白河市 大信蔵戸	H30. 5. 28		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	110	1,000	ND	/	/	/	2.0	ND	0.07	/	920	
		5 相馬市 中村	H30. 5. 25		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	200	1,900	ND	/	/	/	0.79	0.01	0.36	/	390	
		6 会津若松市 二葉町	H30. 5. 23		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	32	300	ND	/	/	/	ND	ND	ND	/	780	
上 水	蛇口水	7 南会津町 糸沢	H30. 5. 23	Bq/ℓ PuはmBq/ℓ	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	11	120	ND	/	/	/	0.97	0.02	0.79	/	260	
		1 福島市 芳木田	H30. 4. 10		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.54	/	/	0.0011	ND	ND	/	ND
海 水	表面水	2 会津若松市 追手町	H30. 4. 5	Bq/ℓ PuはmBq/ℓ	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	/	/	/	/	/	0.047	
		1 相馬市 松川浦沖	H30. 9. 13		0.03	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.013	ND	ND	/	0.0010	ND	ND	/	/
海底土	海底土	1 相馬市 松川浦沖	H30. 9. 13	Bq/kg乾	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.5	ND	/	/	ND	ND	0.22	/	430	
松 葉	二年葉	1 福島市 杉妻町	H30. 5. 15	Bq/kg生	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.0	10	ND	/	ND	/	/	/	/	/	83	
		2 郡山市 嵐山	H30. 8. 21		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	10	ND	/	ND	/	/	/	/	/	84	
		3 白河市 南登り町	H30. 5. 21		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.2	11	ND	/	ND	/	/	/	/	/	74	
		4 会津若松市 城東町	H30. 8. 14		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.3	ND	/	ND	/	/	/	/	/	88	
		5 白河市 南登り町	H30. 5. 15		/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.5	ND	/	ND	/	/	/	/	/	/	79
会津若松市 城東町	H30. 8. 2	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.3	ND	/	ND	/	/	/	/	/	/	80		
	4 会津若松市 城東町	H30. 5. 14	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	/	ND	/	/	/	/	/	/	110		
	5 白河市 南登り町	H30. 8. 13	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.78	ND	/	ND	/	/	/	/	/	/	88		
南会津町 永田	H30. 5. 14	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	/	ND	/	/	/	/	/	56		
	5 南会津町 永田	H30. 8. 1	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	/	ND	/	/	/	/	74		

(注) 1 「ND」：検出限界未満 「/」：対象外核種

5-4 試料採取時の付帯データ集
(原子力発電所周辺等環境放射能測定)

1 上水

No.	採取地点名	採取年月日	気温 (℃)	水温 (℃)	p H
1	いわき市	H30. 4. 3	21.0	12.0	7.6
		H30. 7. 3	30.0	24.0	7.8
2	田村市	H30. 4. 3	15.5	13.0	7.0
		H30. 7. 3	28.9	24.5	8.2
3	広野町	H30. 4. 5	13.1	12.0	7.4
		H30. 7. 3	28.3	25.0	7.7
4	檜葉町	H30. 4. 5	12.2	11.5	7.3
		H30. 7. 3	28.2	25.0	7.2
5	富岡町	H30. 4. 11	18.9	15.0	7.0
		H30. 7. 4	27.5	23.7	7.1
6	川内村	H30. 4. 10	12.3	11.5	7.2
		H30. 7. 4	25.6	22.5	7.7
7	大熊町	—	—	—	—
		—	—	—	—
8	双葉町	—	—	—	—
		—	—	—	—
9	浪江町	H30. 4. 11	16.7	14.5	7.0
		H30. 7. 4	28.5	23.0	7.8
10	葛尾村	H30. 4. 11	12.5	11.5	6.8
		H30. 7. 4	25.4	21.0	7.6
11	南相馬市	H30. 4. 11	16.4	14.0	6.8
		H30. 7. 4	25.9	27.0	7.0
12	飯舘村	H30. 4. 10	12.4	11.0	7.2
		H30. 7. 4	27.7	24.5	7.7
13	川俣町	H30. 4. 10	13.1	11.0	7.0
		H30. 7. 4	26.5	21.0	7.7

2 海水

No.	採取地点名	採取年月日	気温 (℃)	水温 (℃)	p H	Cl^- (‰)
1	第一(発)南放水口付近	H30. 4. 20	12. 5	12. 0	8. 1	18
		H30. 5. 16	23. 0	16. 7	8. 1	18
		H30. 6. 14	13. 5	18. 6	8. 2	18
		H30. 7. 10	26. 0	20. 5	8. 1	19
		H30. 8. 19	22. 0	23. 3	8. 2	19
		H30. 9. 13	22. 0	22. 4	8. 1	17
2	第一(発)北放水口付近	H30. 4. 20	13. 0	12. 0	8. 1	18
		H30. 5. 16	22. 5	16. 2	8. 2	18
		H30. 6. 14	14. 0	18. 6	8. 2	18
		H30. 7. 10	25. 0	22. 3	8. 2	18
		H30. 8. 19	22. 0	23. 3	8. 2	19
		H30. 9. 13	21. 1	22. 3	8. 1	17
3	第一(発)取水口付近 (港湾出入口の外側)	H30. 4. 20	12. 5	12. 1	8. 1	18
		H30. 5. 16	23. 0	16. 8	8. 1	18
		H30. 6. 14	13. 0	18. 6	8. 2	18
		H30. 7. 10	26. 0	22. 7	8. 2	18
		H30. 8. 19	22. 0	23. 3	8. 2	18
		H30. 9. 13	21. 8	22. 3	8. 1	17
4	第一(発)沖合 2 km	H30. 4. 20	14. 0	12. 4	8. 1	18
		H30. 5. 16	23. 5	16. 0	8. 2	18
		H30. 6. 14	16. 5	19. 5	8. 2	18
		H30. 7. 10	26. 5	21. 7	8. 2	18
		H30. 8. 19	22. 0	23. 2	8. 2	19
		H30. 9. 13	21. 0	22. 2	8. 2	17
5	夫沢・熊川沖 2 km	H30. 4. 20	14. 0	12. 2	8. 1	18
		H30. 5. 16	23. 5	16. 0	8. 2	18
		H30. 6. 14	17. 0	20. 4	8. 1	19
		H30. 7. 10	26. 5	21. 5	8. 2	18
		H30. 8. 19	22. 0	23. 0	8. 1	19
		H30. 9. 13	21. 1	22. 2	8. 1	17

6	双葉・前田川沖 2 km	H30. 4. 20	13. 0	11. 8	8. 1	18
		H30. 5. 16	21. 5	16. 5	8. 2	18
		H30. 6. 14	16. 5	19. 2	8. 1	19
		H30. 7. 10	26. 5	22. 2	8. 2	19
		H30. 8. 19	22. 0	23. 3	8. 2	19
7	第二(発)南放水口	H30. 9. 13	21. 0	22. 2	8. 2	17
		H30. 5. 22	23. 3	17. 6	8. 1	19
8	第二(発)北放水口	H30. 9. 6	29. 3	22. 0	8. 1	19
		H30. 5. 22	22. 0	17. 0	8. 2	19
		H30. 9. 6	27. 7	22. 1	8. 1	19

(比較対照地点環境放射能測定)

1 上水

No.	採取地点名	採取年月日	気温 (℃)	水温 (℃)	p H
1	福島市	H30. 4. 10	21. 9	9. 9	7. 2
2	会津若松市	H30. 4. 5	16. 3	12. 0	7. 4

2 海水

No.	採取地点名	採取年月日	気温 (℃)	水温 (℃)	p H	Cl ⁻ (‰)
1	相馬市松川浦沖	H30. 9. 13	27. 0	23. 5	7. 7	16